

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE <div style="text-align: center;">J</div>		PAGE OF PAGES <div style="text-align: center;">1 2</div>	
2. AMENDMENT/MODIFICATION NO. <div style="text-align: center;">0004</div>		3. EFFECTIVE DATE <div style="text-align: center;">03-Sep-2003</div>		4. REQUISITION/PURCHASE REQ. NO. W22W9K-3198-8088		5. PROJECT NO.(If applicable)	
6. ISSUED BY USA ENGINEER DISTRICT, LOUISVILLE ATTN: CELRL-CT 600 DR. MARTIN LUTHER KING PLACE ROOM 821 LOUISVILLE KY 40202		CODE <div style="text-align: center;">DACA27</div>		7. ADMINISTERED BY (If other than item 6) MILITARY/RESERVE TEAM 600 DR. M. L. KING, JR. PL., RM 821 ATTN: TOM E. DICKERT LOUISVILLE KY 40202-2230		CODE <div style="text-align: center;">DACA27</div>	
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)				X		9A. AMENDMENT OF SOLICITATION NO. DACA27-03-B-0008	
				X		9B. DATED (SEE ITEM 11) 21-Jul-2003	
						10A. MOD. OF CONTRACT/ORDER NO.	
						10B. DATED (SEE ITEM 13)	
CODE		FACILITY CODE					
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS							
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.							
12. ACCOUNTING AND APPROPRIATION DATA (If required)							
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.							
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.							
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).							
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:							
D. OTHER (Specify type of modification and authority)							
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.							
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) DACA27-03-B-0008, Access Control Point & Cantonment Fencing, Ft. Knox, KY is amended as follows: SEE ATTACHED SUMMARY OF CHANGES							
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.							
15A. NAME AND TITLE OF SIGNER (Type or print)				16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)			
				TEL: _____ EMAIL: _____			
15B. CONTRACTOR/OFFEROR _____ (Signature of person authorized to sign)		15C. DATE SIGNED		16B. UNITED STATES OF AMERICA BY _____ (Signature of Contracting Officer)		16C. DATE SIGNED 03-Sep-2003	

SUMMARY OF CHANGES**AMENDMENT 0004****SPECIFICATIONS CHANGES FOR ACCESS CONTROL POINT:**

1. Section 00800, paragraph 1.86a. – Delete reference to “E-103-8 thru E-109-8” and replace with “E-104-1 thru E-109-1”.
2. Section 02721, paragraph 2.1.1 – Change “Subsection 805.04.03” to “Subsection 805.03.03”.

CLARIFICATION FOR ACCESS CONTROL POINT:

1. File "E105maxfr.zip" contains a maxFR index file that corrects a viewing problem with the original maxFR Index files where E-105 actually displayed E-106 (E-105 has not changed and was on the original CD-ROM and downloadable ZIP file). This file may be downloaded from the web site under the "plans" drop-down.

DRAWING CHANGES FOR ACCESS CONTROL POINT:

Narrative Changes to Drawings:

1. E-106-O1, Detail C6: Change Key Plan Reference “E-103-O1” to read “E-103”

2. L-105: BARRIER DETAILS

Detail A4: Add general note, “Note: Cable per Detail D6.”

Detail A6: Change dimensions of concrete dead man, 1 ½” Deep to read 18 inches Deep

Detail D6: Change Post label to read, “ 4” STEEL ‘H’ POST GALVANIZED (S4 x 7.7)”
Concrete footing: add diameter dimension -12 inches”

Detail G6: Change label “ 12” DIA. CONCRETE..” to read “ 18” DIA. CONCRETE..”

3. Add the following General Note to L-105: “Cable shall be continuous from deadman to deadman; no splices. Cable shall be U.S. domestic 1 inch 6X19 class wire rope, regular lay, extra improved flow steel (EIFS), independent wire rope core (IWRC), Class A galvanized, in accordance with ASTM A475. Hardware shall be galvanized and provide the same strength as the cable.”

(End of Summary of Changes)